

IND-BARATH ENERGIES (MAHARASHTRA) LTD.

Project Site : Gut No. 161-170,
Karab Khand Gaon (Village),
Mukhed (Taluaq), Nanded (Dist.),
MAHARASHTRA - 431 715.
Ph : 02461-280266, 098909 74746
Fax : 02461-222360



Date: 19.04.2010


To,
S.V. Turbo Group of Engineers,
Patan cheru,
Hyderabad.

Sub: - Boiler Feed water pump commissioning - Reg.

The Boiler Feed Water Pump Overhauled by you and alignment by your technician Mr. Vasu commissioning and load given to boiler for 3:00hrs, 2:15PM to 5:15PM at 61TPH at 71 kg/cm² (G) Pressure. Near pump discharge the pressure is 85 kg/cm² - 92 kg/cm². Both bearings are found ok not getting any Temperature. You have to supply one oil seal for NDE bearing cover. Please arrange the oil seal by 22.04.10, and then we will observe for 6 hours continuously and issue the satisfactory performance certificate the pump. We are satisfied with the performance of the pump.

Yours sincerely,

For Ind Barath Energies (MS) Ltd


A. Sarveswararao. (DGM)